

Damixa Clover, 1-handle basin mixer

Holder/Issued to

FM Mattsson Mora Group Danmark ApS

Hvidkærvej 48, 5250 Odense SV, Denmark

Organisation number: 56416218

Tel: +45 8833 00 34

E-mail: danmark@fmm-mora.com Web: www.damixa.com

Product description

Damixa Clover 1-handle mixer for washbasins. The mixer has adjustable flow restrictor, temperature lock and cartridge with cold start. Mixer is supplied with flexible connection hoses that are covered by Swedish technical approval and have connection G 3/8".

Intended use

Single handle mixer intended for drinking water.

Trade name

1-handle basin mixer,
Damixa Clover Green, Damixa no. 608250000.

Approval

The products satisfy the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

Tap water installations	6:62,	1 st sentence and 2 nd paragraph and general recommendation
Tap water flow	6:623	1 st sentence
Design	6:625,	1 st and 4 th paragraph

Associated documents

Installation instruction Damixa, version 10.20 20242.00

User instruction Damixa, version 12.06 - 12676.00.

Control

The factory production control (FPC) is monitored by an independent inspection body.
Control agreement: 210-17-0103. Inspection body: RISE Research Institutes of Sweden AB.


When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with the requirements stated in the approval and the associated documents. He must also check that the product is accompanied by a manufacturing assurance, which certifies that the product has been manufactured in accordance with the documents on which this approval is based.

Type approval SC0800-17 | 2021-02-03

RISE Research Institutes of Sweden AB | Certification
Box 857, SE-501 15 Borås, Sweden
Tel: +46 10-516 50 00
certifiering@ri.se | www.ri.se



2P02872 (7P03350)



Page 1 (2)

Manufacturing place

Production control includes the following place:
FM Mattsson Mora Group Danmark ApS Odense and production site 912350.

Marking

The products are to be marked at the factory.
The marking consists of a text on every product and packing and includes:

Distributor*

Boverket's registered trade mark
Certification body and accreditation number
Type approval number
Product type designation
Consecutive manufacture year and month*
Inspection body

Damixa



RISE Certifying 1002
SC0800-17
trade name
yy.mm
RISE

*text on mixer

Basis for approval

Report SBF2015F0178 and SBF2015F0177 from Sintef, Norway.
Report K-192852-10-Ko and W-233281-13-Si from Hygiene-Institut des Ruhrgebiets, Germany.
Report KA 0277B/15 and MO 094/16 from TZW, Germany.
Report 2P05293 and 2P05293-01C from RISE Research Institutes of Sweden.

Comments

Mixers are approved in accordance with SS-EN 817.
Test according to NKB 4 is performed in triplicate to verify that migration of Nickel is <80µg.

Classification of sound properties has been approved in accordance with EN ISO 3822.

Group 1: max 20dB (A) Lap at 0,3 MPa.

Group 2: max 30dB (A) Lap at 0,3 MPa.

Group 3: not classified.

The mixers are classified in group 1.

This approval supersedes the previous approval with the same number dated 2017-08-23.

Validity

Valid through 2022-08-22.

The validity of this approval expires when the characteristics included in this approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.