

Type Approval and decision on production control SC0738-17

Damixa Tradition, pillar tap for washbasin

Holder/Issued to

FM Mattsson Denmark ApS

Hvidkærvej 48, 5250 Odense SV, Denmark

Product description

Damixa Tradition, pillar tap for washbasin with G1/2" male thread for connection. Swivel is movable 360°.

Intended use

Single handle mixer intended for drinking water.

Trade name

Damixa Tradition, pillar tap for washbasin, Damixa no. 370160000.

Approval

The products satisfy the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this type approval, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

Tap water installations 6:62, 1st sentence and 2nd paragraph and general recommendation

Tap water flow 6:623, 1st sentence

Design 6:625, 1st och 4th paragraph

The provisions in Section 6:641 "Waste water installations" third paragraph of the Building Regulations (BBR) shall always be considered when installing.

Associated documents

Installation instruction 12598.00, version 2022-09. User instruction 12676.00, version 2021-09.

Control

The factory production control (FPC) is monitored by an independent inspection body. Control plan: Ref no. 210-17-0103, dated 2020-09-10, Inspection body: RISE.

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this type approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this type approval is based.

Manufacturing places

Production control includes the following places:

FM Mattsson Denmark ApS Odense and production site 912350.

Type Approval SC0738-17 | 2022-10-06 RISE Research Institutes of Sweden AB | Certification

Box 857, 501 15 Borås

L+46 10 516 50 00 | certifiering@ri.se | www.ri.se







Type Approval and decision on production control

Marking

The products are to be marked at the factory. The marking consists of a text on every product and packing and includes:

Distributor* Product type designation Consecutive date of production* Type approval number Boverket's registered trade mark RISE Accreditation number Certification body and Inspection body

Damixa see trade name year.week SC0738-17

1002 RISE

Basis for approval

Report 178092-B rev1 from RISE. Reports DL-61173 and DL-43580 from D-Lab. Reports 201700088, 201700204 and 3D101014A from Sintef. Report 365821/8 from DTI.

Comments

Mixers are approved in accordance with SS-EN 817.

Classification of sound properties has been approved in accordance with EN ISO 3822.

Group 1: max 20dB (A) Lap at 0,3 MPa. Group 2: max 30dB (A) Lap at 0,3 MPa.

Group 3: not classified.

The mixers are classified in group 1.

Associated documents shall accompany the product or by other means be available to users of the product. This type approval supersedes the previous type approval with the same number dated 2017-06-30, valid through 2022-06-29.

Validity

Valid through 2027-10-05.

Validity of this type approval can be verified on our website.

The validity of this type approval expires when the type approved products with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.

^{*}text on mixer