

Marking

The products are to be marked at the factory.

The marking consists of a text on every product and packing supplied and includes:

Distributor*	Damixa
Product type designation	trade name
Consecutive manufacture year and month*	yy.mm
Type approval number	SC0778-17
Boverket's registered trade mark	†
RISE Accreditation number	1002
Certification body and Inspection body	RISE

*text on mixer

Basis for approval

Report 032100466-0001 from Kiwa.

Report W-237426kk-13-SI from Hy.

Report 1301059A from DTI.

Report Rapport 8495204-AT1-a from LGA.

Report 8495204-AT1-a from TÜV Rheinland.

Reports 392-2020-00573201_XB_EN and 392-2015-00257401-03 from Eurofins.

Reports 201700371 and 201700088 from Sintef.

Report VTT-S-00142-15 from VTT.

Reports 178092-B rev1, 178092-A, 2P05293 and 2P05293-01ARev1 from RISE.

Comments

Mixer is approved in accordance with SS-EN 200.

Test according to NKB 4 is performed in triplicate to verify that migration of Nickel is <80 µg.

Classification of sound properties has been approved in accordance with EN ISO 3822.

Group 1: max 20dB (A) Lap at 0,3 MPa.

Group 2: max 30dB (A) Lap at 0,3 MPa.

Group 3: not classified.

The mixer is classified in group 1.

Associated documents shall accompany the product or by other means be available to users of the product.

This type approval supersedes the previous type approval with the same number dated 2022-09-06, valid through 2023-03-05.

Validity

Valid through 2028-02-09.

The validity of this type approval can be verified at RISE homepage.

The validity of this type approval expires when the type approved products with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.



Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence

Type Approval SC0778-17 | 2023-02-10

RISE Research Institutes of Sweden AB | Certification