

## Damixa Tradition, 2-handle basin mixer

### Holder/Issued to

**FM Mattsson Denmark ApS**

Hvidkærvej 48, 5250 Odense SV, Denmark.

### Product description

Damixa Tradition 2-handle mixer for washbasins with push up waste valve. Mixers are supplied with flexible connection hoses that are covered by Swedish technical approval and have connection Ø 10 mm.

### Intended use

2-handle mixer intended for hot- and cold tap water.

### Trade name

2-handle mixer,  
Damixa Tradition with connection Ø 10 mm and push up waste valve, Damixa no. 370100000.  
Damixa Tradition with connection Ø 10 mm and push up waste valve, Damixa no. 370290000.

### Approval

The products satisfies the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this type approval, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

|                         |   |
|-------------------------|---|
| Tap water installations | 6:62, 1st sentence and 2nd paragraph and general recommendation |
| Tap water flow          | 6:623, 1st sentence   |
| Design                  | 6:625, 1st and 4th paragraph                                    |

### Associated documents

Installation instruction 20025.00, dated 2022-09.  
User instruction 12676.00, dated 2021-09.

### Control

The factory production control (FPC) is monitored by an independent inspection body.

Control plan: Ref no. 210-17-0103 dated 2020-09-10, Inspection body: RISE

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this type approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this type approval is based.

### Manufacturing places

Production control includes the following places:  
FM Mattsson Denmark ApS Odense and production site 912350.

Type Approval SC0737-17 | 2023-02-17


**RISE Research Institutes of Sweden AB | Certification**

Box 857, 501 15 Borås

+46 10 516 50 00 | [certifiering@ri.se](mailto:certifiering@ri.se) | [www.ri.se](http://www.ri.se)

1152720

This document is the property of RISE and may not be reproduced other than in full, except with the prior written approval by RISE



Akkred. nr. 1002  
Produktcertifiering  
ISO/IEC 17065

## Marking

The products are to be marked at the factory. The marking consists of a text on every product and packing supplied and includes:

|   |            |
|---|------------|
| Distributor*                            | Damixa     |
| Product type designation                | trade name |
| Consecutive manufacture year and month* | yy.mm      |
| Type approval number                    | SC0737-17  |
| Boverket's registered trade mark        | †          |
| RISE Accreditation number               | 1002       |
| Certification- and Inspection body      | RISE       |

\*text on mixer

## Basis for approval

Reports 178092-B rev1 and 178092-A from RISE.  
Reports 201700088, 201700204 and 3D101014A from Sintef.

## Comments

Mixers are approved in accordance with SS-EN 200.

Classification of sound properties has been approved in accordance with EN ISO 3822.

Group 1: max 20 dB(A) Lap at 0,3 MPa.

Group 2: max 30 dB(A) Lap at 0,3 MPa.

Group 3: not classified.

The mixers are classified in group 1.

Associated documents shall accompany the product or by other means be available to users of the product.

This type approval supersedes the previous type approval with the same number dated 2018-03-19, valid through 2023-03-18.

## Validity

Valid through 2028-02-16.

The validity of this type approval can be verified at RISE homepage.

The validity of this type approval expires when the type approved products with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.



Stefan Coric

*This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence.*