

Control

The factory production control (FPC) is monitored by an independent inspection body.

Control plan: Ref no. CR074 dated 2018-10-10 Inspection body: RISE

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this type approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this type approval is based.

Manufacturing places

Production control includes the following places:

FM Mattsson Denmark ApS Odense and production site 912350

Marking

The products are to be marked at the factory. The marking consists of a text on every product and packing supplied and includes:

Distributor*	Damixa
Product type designation	see trade name
Consecutive date of production*	year.week
Type approval number	SC0762-17
Boverket's registered trade mark	†
RISE Accreditation number	1002
Inspection body	RISE

*text on mixer

Basis for approval

Reports 178092-B rev1, 7P04475E and 1206213-A_rev1 from RISE.

Reports DL-61173 and DL-43580 from D-Lab.

Report 392-2015-00322701 rev. 2 from Eurofins.

Report SBF2015F0452 and 202300183 from Sintef.

Report 57214216-1 from LGA.

Comments

Mixers are approved in accordance with SS-EN 817.

Test according to NKB 4 is performed in triplicate to verify that migration of Nickel is <80 µg.

Classification of sound properties has been approved in accordance with EN ISO 3822.

Group 1: max 20dB (A) Lap at 0,3 MPa.

Group 2: max 30dB (A) Lap at 0,3 MPa.

Group 3: not classified.

The mixers are classified in group 1

Associated documents shall accompany the product or by other means be available to users of the product.

This type approval supersedes the previous type approval with the same number dated 2022-09-26.

Type Approval SC0762-17 | 2024-08-27

RISE Research Institutes of Sweden AB | Certification

Validity

Valid through 2027-09-25.

The validity of this type approval can be verified at RISE homepage.

The validity of this type approval expires when the type approved products with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

A handwritten signature in blue ink, appearing to read 'Stefan Coric'.

Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence.