

Damixa Tradition, dual lever kitchen mixer

Holder/Issued to

FM Mattsson Denmark ApS

Hvidkærvej 48, 5250 Odense SV, Denmark

Product description

Damixa Tradition, dual lever wall mixer for kitchen with c/c 150 mm and outlet with 1/2" male thread. Eccentric unions and wall plates are enclosed in packaging.

Intended use

Dual lever wall mixer intended for drinking water.

Trade name

Damixa Tradition, kitchen mixer for wall mounting, Damixa no. 370460000

Approval

The products satisfies the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this type approval, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR) issued by the National Board of Housing, Building and Planning.

Tap water installations

6:62, 1st sentence and 2nd paragraph and general recommendation

Tap water flow

6:623, 1st sentence

Design

6:625, 1st och 4th paragraph

Associated documents

Installation instruction 20032.00, version 2022-09

User instruction 12676.00, version 2021-09

Control

The factory production control (FPC) is monitored by an independent inspection body.

Control plan: Ref no. CR074 dated 2018-10-10, Inspection body: RISE

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this type approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this type approval is based.

Manufacturing places

Production control includes the following places:

FM Mattsson Denmark ApS Odense and production site 912350.

Type Approval SC0741-17 | 2025-02-01


RISE Research Institutes of Sweden AB | Certification

Box 857, 501 15 Borås

☎ +46 10 516 50 00 | certifiering@ri.se | www.ri.se

1282633


This document is the property of RISE and may not be reproduced other than in full, except with the prior written approval by RISE



Akkred. nr. 1002
Produktcertifiering
ISO/IEC 17065

Marking

The products are to be marked at the factory. The marking consists of a text on every product and packing supplied and includes:

Distributor*	Damixa
Product type designation	trade name
Consecutive date of production*	yy-mm
Type approval number	SC0741-17
Boverket's registered trade mark	
RISE Accreditation number	1002
Inspection body	RISE

*marking on mixer

Basis for approval

Report 178092-B rev1, 7P04475-20, 1293419-A and 1293419-B from RISE.
Report DL-61173 and DL-43580 from D-Lab.
Report 201700088, 3B038317 and 202201249 from Sintef.
Report 392-2015-00323801 from Eurofins.

Comments

Mixers are approved in accordance with SS-EN 200.
Test according to NKB 4 is performed in triplicate to verify that migration of Nickel is <80 µg.

Classification of sound properties has been approved in accordance with EN ISO 3822.
Group 1: max 20dB (A) Lap at 0,3 MPa
Group 2: max 30dB (A) Lap at 0,3 MPa
Group 3: not classified

The mixers are classified in group 1.

Associated documents shall accompany the product or by other means be available to users of the product.

This type approval supersedes the previous type approval with the same number dated 2022-10-06

Validity

Valid through 2027-10-05.

The validity of this type approval can be verified at RISE homepage.
The validity of this type approval expires when the type approved product with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.



Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence.