

# Damixa Bell, 1-handle basin and kitchen mixer

Holder/Issued to

## FM Mattsson Mora Group Danmark ApS

Østbirkvej 2, 5240 Odense NØ, Denmark.

Organisation number: 56416218.

Tel: +45 63102210, fax: +45 63102209

E-mail: [danmark@fmm-mora.com](mailto:danmark@fmm-mora.com) Web: [www.damixa.com](http://www.damixa.com)

### Product description

Damixa Bell 1-handle mixer for kitchen and basin. Kitchen mixers can be equipped with or without shut off valve for dishwasher. Washbasin mixers can be equipped with or without push up waste valve. The mixers have adjustable flow restrictor, temperature lock and swivel is limited to 120°. Mixers are supplied with flexible connection hoses that are covered by Swedish technical approval and have connection G 3/8" or Ø 10 mm.

### Intended use

Single handle mixer intended for drinking water.

### Trade name

1-handle kitchen mixer,

Damixa Bell with dishwasher shut off and connection Ø 10 mm, Damixa no. 900010000.

Damixa Bell with dishwasher shut off and connection G 3/8", Damixa no. 900010038.

Damixa Bell with connection Ø 10 mm, Damixa no. 900470000.

Damixa Bell with connection G 3/8", Damixa no. 900470038.

Damixa Bell with C-spout, dishwasher shut off and connection Ø 10 mm, Damixa no. 900710000.

Damixa Bell with C-spout, dishwasher shut off and connection G 3/8", Damixa no. 900710038.

Damixa Bell with C-spout and connection Ø 10 mm, Damixa no. 900770000.

Damixa Bell with C-spout and connection G 3/8", Damixa no. 900770038.

Damixa Bell Black with C-spout and connection Ø 10 mm, Damixa no. 900776000.

Damixa Bell Black with C-spout and connection G 3/8", Damixa no. 900776038.

Damixa Bell Pro with flexible spout and connection G 3/8", Damixa no. 901280000.

Damixa Bell Pro with flexible spout, dishwasher shut off and connection G 3/8", Damixa no. 901580000.

1-handle basin mixer,

Damixa Bell with C-spout and connection Ø 10 mm, Damixa no. 908170000.

Damixa Bell with C-spout and connection G 3/8" Damixa no. 908170038.

Damixa Bell with C-spout, push up waste valve and connection Ø 10 mm, Damixa no. 908270000.

Damixa Bell with C-spout, push up waste valve and connection G 3/8", Damixa no. 908270038.

Damixa Bell with push up waste valve and connection Ø 10 mm, Damixa no. 908470000.

Damixa Bell with push up waste valve and connection G 3/8", Damixa no. 908470038.

Damixa Bell with connection Ø 10 mm, Damixa no. 908570000.

Damixa Bell with connection G 3/8", Damixa no. 908570038.

Type approval SC0784-17 | 2019-05-17

RISE Research Institutes of Sweden AB | Certification


Box 857, SE-501 15 Borås, Sweden

Tel: +46 10-516 50 00

certifiering@ri.se | www.ri.se



9P00535



Page 1 (3)

### Approval

The products satisfy the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

Tap water installations\*

6:62, 1<sup>st</sup> sentence and 2<sup>nd</sup> paragraph and general recommendation

Tap water flow  
Design

6:623 1<sup>st</sup> sentence  
6:625, 1<sup>st</sup> and 4<sup>th</sup> paragraph

\*Mixers comply with Boverket's (the National Board of Housing, Building and Planning) updated threshold value for max. amount of dissolved lead as described in BBR 21, 2014-06-17.

### Associated documents

Installation instruction Damixa, version 10.16 – 20174.  
User instruction Damixa, version 12.06 - 12676.00.

### Control

The factory production control (FPC) is monitored by an independent inspection body.  
Control agreement: 210-17-0103. Inspection body: RISE Research Institutes of Sweden AB.

When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with the requirements stated in the approval and the associated documents. He must also check that the product is accompanied by a manufacturing assurance, which certifies that the product has been manufactured in accordance with the documents on which this approval is based.

### Manufacturing place

Production control includes the following place:  
FM Mattsson Mora Group Danmark ApS Odense.

### Marking

The products are to be marked at the factory.  
The marking consists of a text on every product and packing and includes:

Distributor\*  
Boverket's registered trademark  
Certification body and accreditation number  
Type approval number  
Product type designation  
Consecutive manufacture year and month\*  
Inspection body

Damixa  
†  
RISE Certifiering 1002  
SC0784-17  
*trade name*  
yy.mm  
RISE

\*text on mixer

### Basis for approval

Report 9P03102 from RISE Research Institutes of Sweden AB.  
Report 392-2016-00275001-03 rev1 and 392-2016-00275201-03 rev1 from Eurofins, Denmark.  
Report 57214216-01 from LGA TÜV Rheinland, Germany.  
Report 201700642 from Sintef, Norway.  
Report VTT-S-00142-15 from VTT, Finland.

Type approval SC0784-17 | 2019-05-17

RISE Research Institutes of Sweden AB | Certification

### Comments

Mixers are approved in accordance with SS-EN 817.

Test according to NKB 4 is performed in triplicate to verify that migration of Nickel is  $<80\mu\text{g}$ .

Classification of sound properties has been approved in accordance with EN ISO 3822.

Group 1: max 20dB (A) Lap at 0,3 MPa.

Group 2: max 30dB (A) Lap at 0,3 MPa.

Group 3: not classified.

The mixers are classified in group 1.

### Validity

Valid through 2023-01-07.

The validity of this approval expires when the characteristics included in this approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

Ronald Green

Marcus Tillman