


Manufacturing places

Production control includes the following places:
FM Mattsson Denmark ApS Odense and production site 912350.

Marking

The products are to be marked at the factory. The marking consists of a text on every product and packing and includes:

Distributor*	Damixa
Product type designation	<i>see trade name</i>
Consecutive date of production*	<i>year.week</i>
Type approval number	SC0720-17
Boverket's registered trade mark	
RISE Accreditation number	1002
Certification body and Inspection body	RISE

*text on mixer

Basis for approval

Report 178092-B rev1 and 7P04475E from RISE.
Reports DL-61173 and DL-43580 from D-Lab.
Report 317305B from DTI.
Report 392-2016-00195001 from Eurofins.
Report 201700088 from Sintef.

Comments

Mixers are approved in accordance with SS-EN 200.
Test according to NKB 4 is performed in triplicate to verify that migration of Nickel is <80 µg.

Classification of sound properties has been approved in accordance with EN ISO 3822.
Group 1: max 20dB (A) Lap at 0,3 MPa.
Group 2: max 30dB (A) Lap at 0,3 MPa.
Group 3: not classified.
The mixers are classified in group 1.

Associated documents shall accompany the product or by other means be available to users of the product.
This type approval supersedes the previous type approval with the same number dated 2017-07-24, valid through 2022-07-23.

Validity

Valid through 2027-10-05.

Validity of this type approval can be verified on our website.

The validity of this type approval expires when the type approved products with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.



Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.
Type Approval SC0720-17 | 2022-10-06