

Manufacturing places

Production control includes the following places:
FM Mattsson Danmark ApS Odense and production site 912350.

Marking

The products is to be marked at the factory. The marking consists of a text on every product and packing supplied and includes:

Distributor*	Damixa
Product type designation	trade name
Consecutive manufacture year and month*	yy.mm
Type approval number	SC0767-17
Boverket's registered trade mark	†
RISE Accreditation number	1002
Certification body and Inspection body	RISE

*text on mixer

Basis for approval

Reports 178092-B rev1 and 7P04475-18B from RISE.
Report 475720D from DTI.
Report 57214216-01 from LGA.
Report 392-2017-00163301_XB_EN from Eurofins.

Comments

Mixers are approved in accordance with SS-EN 817.
Test according to NKB 4 is performed in triplicate to verify that migration of Nickel is <80 µg.

Classification of sound properties has been approved in accordance with EN ISO 3822.

Group 1: max 20dB (A) Lap at 0,3 MPa.

Group 2: max 30dB (A) Lap at 0,3 MPa.

Group 3: not classified.

The mixer are classified in group 1.

Associated documents shall accompany the product or by other means be available to users of the product.

This type approval supersedes the previous type approval with the same number dated 2022-09-06, valid through 2023-03-05.

Validity

Valid through 2028-02-09.

The validity of this type approval can be verified at RISE homepage.

The validity of this type approval expires when the type approved product with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.



Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence.

Type Approval SC0767-17 | 2023-02-10

RISE Research Institutes of Sweden AB | Certification