

Marking

The product is to be marked at the factory. The marking consists of a text on every product and packing and includes:

Distributor*	Damixa
Product type designation	<i>see trade name</i>
Consecutive date of production*	<i>year.week</i>
Type approval number	SC0766-17
Boverket's registered trade mark	†
RISE Accreditation number	1002
Certification- and Inspection body	RISE

* text on mixer

Basis for approval

Report 032100466-0001 from Kiwa.
Report W-237426kk-13-SI from Hy.
Report 57214216-01 and 7310441-01 from LGA.
Report SBF2015F0177b from Sintef.
Report 2P05293 and 2P05293-01C from RISE.

Comments

The mixer is approved in accordance with SS-EN 817.
Test according to NKB 4 is performed in triplicate to verify that migration of Nickel is < 80 µg.

Classification of sound properties has been approved in accordance with EN ISO 3822.

Group 1: max 20 dB(A) Lap at 0,3 MPa.

Group 2: max 30 dB(A) Lap at 0,3 MPa.

Group 3: not classified.

The tap valve is classified in group 1.

Associated documents shall accompany the product or by other means be available to users of the product.

This type approval supersedes the previous type approval with the same number dated 2022-09-06, valid through 2023-03-05.

Validity

Valid through 2028-02-09.

The validity of this type approval can be verified at RISE homepage.

The validity of this type approval expires when the type approved products with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.



Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence.