

Control

The factory production control (FPC) is monitored by an independent inspection body.

Control plan: Ref no. CR074 dated 2018-10-10 Inspection body: RISE

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this type approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this type approval is based.

Manufacturing places

Production control includes the following places:

FM Mattsson Denmark ApS Odense and production site 912350

Marking

The products are to be marked at the factory. The marking consists of a text on every product and packing supplied and includes:

Distributor*	Damixa
Product type designation	see trade name
Consecutive date of production*	year.week
Type approval number	SC0765-17
Boverket's registered trade mark	†
RISE Accreditation number	1002
Inspection body	RISE

Basis for approval

Report 032100466-0001 from Kiwa

Reports 178092-B rev1, 178092-A, 2P05293-01ARev1, 2P05293 and 1206213-A_rev1 from RISE

Report W-237426kk-13-SI from Hy

Reports 319587, 320151, 319725A 319725B and 319725C from DTI

Report 57214216-1 from LGA

Report VTT-S-00142-15 from VTT

Report 202300183 from Sintef

Comments

Mixers are approved in accordance with SS-EN 817.

Classification of sound properties has been approved in accordance with EN ISO 3822.

Group 1: max 20dB (A) Lap at 0,3 MPa.

Group 2: max 30dB (A) Lap at 0,3 MPa.

Group 3: not classified.

The mixers are classified in group 1.

Associated documents shall accompany the product or by other means be available to users of the product.

This type approval supersedes the previous type approval with the same number dated 2023-02-10.

Validity

Valid through 2028-02-09.

The validity of this type approval can be verified at RISE homepage.

The validity of this type approval expires when the type approved products with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

A handwritten signature in blue ink, appearing to read 'Stefan Coric'.

Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence.